

<b>FORMAT F.1</b>				
<b>Format for Query / Clarification / Deviation (QCD)</b>				
Tender No: TPNODL/OT/2022-23/22N32 Dt. 27.04.22				
Package Name: RATE CONTRACT FOR SUPPLY OF 33kV, 11kV POTENTIAL & CURRENT TRANSFORMER in TPNODL Area				
Note :	The said format to be used only for any Pre-bid Query / Clarification/ Deviation on any of the Tender documents			
<b>Sr. No.</b>	<b>Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No</b>	<b>Description as per Bid Document</b>	<b>Query / Clarification / Deviation</b>	<b>TPNODL Response</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>
<b>AS PER REVISED SPECIFICATION</b>				
4	Tender Doc. No.TPNODL-ENG-ELC-017 (Specification of 11KV & 33KV Outdoor Type Potential Transformer) Point No.4 Page No.3 of 12 (GENERAL TECHNICAL REQUIREMENTS)	<b>11KV Single Phase PT</b> 11000/√3/110/√3/110/√3V Winding I : 50VA, 3P Winding II : 50VA, 0.2	<ul style="list-style-type: none"> <li>We refer to the technical Specification for the 11KV PT having PTR: 11000/√3/110/√3/110/√3V, Two Winding, we suggest to have the PT to manufacture &amp; supply with following Spect.:-               <ul style="list-style-type: none"> <li>A) Wdg. I – 25VA, 3P</li> <li>B) Wdg. II -25VA, 0.2</li> </ul> </li> </ul> due to technical limitation as 50VA is high for 0.2 class accuracy.	Bidder has to comply as per TS.