



Response to Pre-Bid Queries

TPNODL/OT/2021-22/199

Tender Description: Rate Contract for Supply of PSC Pole 9 M & 11 M

The pre-bid queries as received against the referred tender enquiry and TPNODL's responses on the same are placed below:

S. No.	Tender Reference	Bidder's Pre-Bid Query	TPNODL's Response
01.	As per clause No.08	"Security Cum performance Deposit", it has been mentioned that, we have to pay 10% PO value if purchase order value is less than Rs 5 Crores which is very high.	It should be as per tender enquiry as well as GCC-TPNODL.
02.	Technical Specification	We required Drawing and Catalogue of 11 Mtr PSC Pole.	Kindly follow the technical specification points for drawing. During the time of tender technical evaluation, we will see if any amendment is required or not.
03.	Annexure I	The locations of unloading points of psc poles for the 5 district of TPNODL. It may help to quote the freight charges.	Please consider BOQ, we are asking rates according the TPNODL- Circle. However, exact delivery location shall be specified in release order. Quoted Price shall be FOR TPNODL Odisha Locations & inclusive of Transit Insurance, Forwarding Charges and shall be inclusive of the unloading at TPNODL Location.
04.	In the tender, the working load of 11mtr. PSC Poles is specified as 350kgs	We have been supplying 11mtr. PSC Poles of 300kgs WL in the past to NESCO and other private parties	Comply as per TPNODL technical specification.
05.	Raw materials, Steel and Cement, have been specified to be purchased from certain brands. Here other brands are available, which are equally good in quality, giving consistent results in the past years	Kindly allow us to use the raw materials sourced from other suppliers too.	Comply as per TPNODL technical specification.



Response to Pre-Bid Queries

TPNODL/OT/2021-22/199

Tender Description: Rate Contract for Supply of PSC Pole 9 M & 11 M

S. No.	Tender Reference	Bidder's Pre-Bid Query	TPNODL's Response
06.	The bidder should have been supplied minimum 3000 Poles of 9/11 M in last three years. Copy of work orders / completion certificate to be submitted in this regard.	Here we want to submit that during the last three years we have made institutional and private sales of the around 25,000 nos. of 8mtr/9mtr/10mtr PSC Poles. Previously 9mtr. and 11mtr poles were not in regular demand by Discoms.	It should be as per tender enquiry only.
07.	Bidder has to mandatorily quote as per schedule of item [Annexure-I]. Failing to do so TPNODL may reject the bid	we are manufacturing the 8 Meter and 9 Meter PSC Pole only. We can only Bid for 9 Mtr poles. Henceforth you please confirm to us what we should mention in your price format of 11M row.	It should be as per tender enquiry only.

Note: - This document shall form an integral part of tender and should be submitted along with the tender document.