

<b>FORMAT F.1</b>				
<b>Format for Query / Clarification / Deviation (QCD)</b>				
Tender No: TPNODL/OT/2022-23/25N06 Dt. 10.05.22				
Package Name: RATE CONTRACT FOR SUPPLY OF 33kV, 11kV CU & MU in TPNODL Area				
Note :	The said format to be used only for any Pre-bid Query / Clarification / Deviation on			
Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	TPNODL Response
1	2	3	4	5
1	Clause no. 7.1 Special conditions of contract	Delivery period shall be 8 weeks from the approval of GTPs and drawings.	Delivery will be 120 days from receipt of RO. Justification:- i. Procurement of Raw material-25 days ii. Manufacturing and testing-60 days iii. Deputation of Inspector-15 days iv. DI from TPNODL-5 days v. PDI- 5 days vi. Transit time-10 days Total-120 days Note: Please consider 90 days delivery for future Tenders. The period if inspection, DI & transit time itself is eating up 15-20 days unnecessary LD gets levied.	<b>comply as per specs</b>
2	Annexure VI point no. 12	The original price bids of the bidders shall be reduced on pro-rata basis against each line item based on the final all inclusive prices offered during conclusion of the auction event for arriving at Contract amount.	Instead of allowing us to bid only the total package price, kindly allow us to submit bid against each line item.	Evaluation will be done as per Groups only.
3	As per Technical Specification of 33kV Unit clause no. 3.2 (vi)	Short time thermal current ant its duration. 25kA for 1 sec.	The short circuit current duration for 33kV of 25kA for 1 sec. is very high for small ratios like 10/5A, 15/5A, 20/5A, 30/5A, & 400/5A Request you to reduce this to 6.4kA for 1 sec up to 10/5A, 15/5A, 20/5A & 30/5A 13.1kA for 1 sec for 400/5A. Also TPSODL, TPWODL, TPCODL have STC ratings of 6kA for 1 sec. up to 30A & 13.1kA for 1 sec. above 50A.	<b>For 33 KV MC / MU- 5/5 to 15/5 A STC is 3 KA for 0.5 Sec, 20/5 A &amp; 15/5 A STC is 7.88 KA for 0.5 Sec, for 50/5 A &amp; above it is 13.1 KA for 1 Sec. For 200/5, 300/5 &amp; 400/5 A STC is 26.3 KA for 1 Sec</b>
4	As per Technical Specification clause no. 4.4(Design)	All bolts, nuts, washers in contact with non-ferrous parts shall be of brass.	As per clause no 4.4 mentioned is All bolts, nuts, washers in contact with non-ferrous parts shall be of brass. & as per clause no 4.0 All ferrous parts including bolts & nuts liable to corrosion, forming integral part of the equipment shall be SS. Kindly clarify.	<b>All bolts, nuts, washers in contact with non-ferrous parts shall be of brass.</b>
5	As per Technical Specification clause no. 4.0 (Design)	All ferrous parts including bolts & nuts liable to corrosion, forming integral part of the equipment shall be SS.		

Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	TPNODL Response
6	As per Technical Specification clause 13.2 Acceptance and Routine Tests:-	Air pressure test on empty tank of transformer opened for physical verification test (One per each lot offered during pre-dispatch inspection.	This clause not feasible at the time of Inspection because the CT-PT unit is hermetically sealed. The clause may be deleted.	OK
7	As per ANNEXURE – I GUARANTEED TECHNICAL PARTICULARS (B) (iv) of 33kV Unit.	Class of accuracy 0.2S for PT	As per IS-3156/1992 applicable class of accuracy 0.2 Kindly clarify.	Class of accuracy 0.2 for PT
8	As per Technical Specification of 11kV Unit clause no. 3.0 (vi)	Short time thermal current ant its duration. 16kA for 1 sec.	The short circuit current duration for 11kV of 16kA for 1 sec. is very high for small ratios like 5/5A, 10/5A, 15/5A, 20/5A, & 200/5A. Request you to reduce this to 6.4kA for 1 sec up to 5/5A, 10/5A, 15/5A & 20/5A 13.1kA for 1 sec for 200/5A. Also TPSODL, TPWODL, TPCODL have STC ratings of 6kA for 1 sec. up to 30A & 13.1kA for 1 sec. above 50A.	OK
9	Clause no. 7.1 Special conditions of contract	Post award of rate contract, Business Associate (BA) shall submit applicable Performance Bank Guarantee as per GCC within 15 days. PBG applicable shall 5% of Rate Contract Value. PBG submitted, shall be released after completion of applicable guarantee period plus one month.	As per Government of India notification dtd. 30.12.2021 all BGs to be 3% max. (Copy enclosed). So request you to amend this clause to 3% PBG.	As per Tender Only